



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague

Akreditované zkušební laboratoře, Autorizovaná osoba,
Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 00 Praha 10



CERTIFICATE
OF CONSTANCY OF PERFORMANCE

1390 – CPR – 0342/12/P

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Factory made mineral wool products used for building equipment and industrial instalations, sold under the trade mark

Alu Lamella Mat; Larock 40 ALS
Klimafix; Ventizol

(trade marks and type codes according to list given in the annex to the certificate)

Methods of measurement and product description are listed in the report
No. 1390-CPR-0342/12/P-2015 from 10. 04. 2015

produced by :

ROCKWOOL Polska, Sp.z o.o.
ul. Kwiatowa 14
66-131 Cigacice, Poland

**and produced in the :
manufacturing plant**

ROCKWOOL Polska, Sp.z o.o.
ul. Kwiatowa 14
66-131 Cigacice, Poland (production line CIG 4)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 14 303:2009 + A1:2013

under system 1 are applied and that the product fulfills all the prescribed requirements set out above.

This certificate was first issued on 08. 08. 2012 as a certificate in accordance with CPD and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Notified Body 1390
Prague, 10. 04. 2015




Ing. Petr Kučera, CSc.
Deputy of Notified Body 1390



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague

Akreditované zkušební laboratoře, Autorizovaná osoba,
Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 21 Praha 10



Annex to the CERTIFICATE OF CONSTANCY OF PERFORMANCE
1390-CPR-0342/12/P

The certificate covers the following products of Rockwool Polska Sp. z o.o.,
ul. Kwiatowa 14, 66-131 Cigacice, Poland

tab 1

| Trade mark | Thermal conductivity W/m·K | Reaction to fire | Type code in accordance with EN 14 303 |
|----------------------------------|----------------------------|------------------|--|
| Alu Lamella Mat Larock 40 ALS | see tab. 2 | A1 | MW EN 14303-T4-ST(+)250-WS1-MV2 |
| Klimafix Ventizol | | A2-s1;d0 | MW EN 14303-T4-ST(+)50-WS1-MV2 |

tab 2

| Trade mark | λ_D Thermal dependence of thermal conductivity W/m·K | | | | | | | |
|----------------------------------|--|-------|-------|-------|-------|-------|---|---|
| | 10 | 50 | 100 | 150 | 200 | 250 | - | - |
| Alu Lamella Mat Larock 40 ALS | 0,038 | 0,050 | 0,061 | 0,076 | 0,096 | 0,118 | - | - |

| Trade mark | λ_D Thermal dependence of thermal conductivity W/m·K | | | | | | | |
|----------------------|--|-------|-------|-------|-------|---|---|---|
| | 10 | 20 | 30 | 40 | 50 | - | - | - |
| Klimafix Ventizol | 0,038 | 0,040 | 0,042 | 0,044 | 0,048 | - | - | - |

Notified Body 1390
Prague, 10. 04. 2015




Ing. Petr Kučera, CSc.
Deputy of Notified Body 1390